

Iditarod Area-Blackwell School Heating Renovation/Site Repair (ED 36)

FY2002 Request: \$173,754
Reference No: AMD 34789

AP/AL: Appropriation

Category: Education

Location: Anvik

House District: Rural Interior (HD 36)

Estimated Project Dates: 07/01/2001 - 06/30/2006

Project Type: Deferred Maintenance

Recipient: Iditarod Area Schools

Contact: Karen J. Rehfeld

Contact Phone: (907)465-8650

Brief Summary and Statement of Need:

Amendment # 13: The 8,240 square foot K-12 and the existing heating system are 21 years old. System failures have resulted in interior oil spills and exhaust fumes forcing the school to close until the necessary repairs could be made. The Division of Energy has completed design plans for a new boiler system and waste heat connection to the Alaska Village Electric Corporation. The installation will require a modular building and twin boilers with a heat exchanger retrofit. The district has undertaken this work and the project is complete.

Funding:	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>FY2007</u>	<u>Total</u>
NTSC Bond	\$173,754						\$173,754
Total:	\$173,754	\$0	\$0	\$0	\$0	\$0	\$173,754

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Additional Information / Prior Funding History: