

**Bethel Hangar Fuel Tank Replacement and Rural Trooper Housing Water and Sewer Systems**      **FY2003 Request: \$89,000**  
**Reference No: 35707**

**AP/AL:** Appropriation      **Project Type:** Health and Safety  
**Category:** Public Protection  
**Location:** Statewide      **Contact:** Kenneth E. Bischoff  
**House District:** Statewide (HD 1-40)      **Contact Phone:** (907)465-4336  
**Estimated Project Dates:** 07/01/2002 - 06/30/2005

**Brief Summary and Statement of Need:**

This project request will replace the Bethel Aircraft Hangar fuel tank and replace the rural trooper housing water and sewer systems in Aniak and Nenana.

<b>Funding:</b>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>FY2007</u>	<u>FY2008</u>	<u>Total</u>
Gen Fund	\$89,000						\$89,000
<b>Total:</b>	\$89,000	\$0	\$0	\$0	\$0	\$0	\$89,000

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

**Operating & Maintenance Costs:**

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
<b>Totals:</b>	<b>0</b>	<b>0</b>

**Additional Information / Prior Funding History:**

None

**Project Description/Justification:**

**PROJECT DESCRIPTION:**

This project request will replace the Bethel Aircraft Hangar fuel tank and replace the rural trooper housing water and sewer systems in Aniak and Nenana.

**PROJECT NEED:**

Fuel tank replacement at the Bethel aircraft hangar.

Rural Trooper Housing - Aniak Sewer Line--Replace the 40+ year old existing sewer line with ABS arctic pipe. The old line has been plagued with freeze-ups, blockages and marginal repairs. The line runs underneath a roadway which causes the frost line to be driven down.

Rural Trooper Housing Nenana Well- Drill a new well in a different location to replace the old driven well that has very poor production and is too close to the septic system.

Rural Trooper Housing Nenana Septic System --Replace 12 to 15 year old shallow system that does not have the State minimum 100ft. separation from the well.

**ANALYSIS OF ESTIMATED OPERATING COSTS**

No additional operating costs will be incurred as a result of this project.

**IMPACT OF NOT RECEIVING REQUEST**

**Bethel Hangar Fuel Tank Replacement and Rural Trooper  
Housing Water and Sewer Systems**

**FY2003 Request:  
Reference No:**

**\$89,000  
35707**

---

The only alternative solution would be to lease space rather than occupy state-owned housing units. This would result in additional operational lease costs.