

Denali Borough - Cantwell School Heating and Sprinkler System

FY2001 Request: \$668,125
Reference No: AMD 33570

AP/AL: Appropriation

Project Type: Health and Safety

Category: Education

Location: Cantwell

Contact: Karen J. Rehfeld

House District: North Pole, Denali (HD 34)

Contact Phone: (907)465-8650

Estimated Project Dates: 07/01/2000 - 06/30/2005

Brief Summary and Statement of Need:

This project is the FY2001 Major Maintenance Grant Fund Priority #44 and is scheduled to begin in FY2002.

Funding:	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$668,125						\$668,125
Total:	\$668,125	\$0	\$0	\$0	\$0	\$0	\$668,125

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	
Totals:	0	0

Additional Information / Prior Funding History:

Project Description/Justification:

This project will install automatic sprinkler heads in all spaces of the 26-year-old, 17,141 square foot Cantwell School, a 10,000-gallon water tank, and a fire pump to feed the supply line. No fire protection system currently exists in the 27-year-old, 17,141 square foot building. The project will also replace six oil-fired heaters with one central oil-fired heater and hydronic piping throughout the structure, saving \$1,100 per year in fuel and maintenance costs. Proposed cost: \$954,465.