

**Chugach - Whittier Fire Alarm Replacement****FY2001 Request: \$40,431**  
**Reference No: AMD 33578****AP/AL:** Appropriation**Project Type:** Health and Safety**Category:** Education**Location:** Whittier**Contact:** Karen J. Rehfeld**House District:** Delta, Prince William Sound (HD**Contact Phone:** (907)465-8650

35)

**Estimated Project Dates:** 07/01/2000 - 06/30/2005**Brief Summary and Statement of Need:**

This project is the FY2001 Major Maintenance Grant Fund Priority #52 and is scheduled to begin in FY2002.

<b>Funding:</b>	<u>FY2001</u>	<u>FY2002</u>	<u>FY2003</u>	<u>FY2004</u>	<u>FY2005</u>	<u>FY2006</u>	<u>Total</u>
AHFC Bonds	\$40,431						\$40,431
<b>Total:</b>	\$40,431	\$0	\$0	\$0	\$0	\$0	\$40,431

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

**Operating & Maintenance Costs:**

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
<b>Totals:</b>	<b>0</b>	<b>0</b>

**Additional Information / Prior Funding History:****Project Description/Justification:**

This project will replace the existing fire alarm system in an 11,242 square foot section of the 23,434 square foot, 46-year-old school. It will also install a new enunciator panel and magnetic hold-open devices on all classroom doors. The age of the existing system is not known, but it was in place during a 1985 renovation project. Periodic inspections reveal failure of an increasing number of detectors. Parts for the aging system are difficult to find and take significant time to secure. Proposed cost: \$41,256.