

Reappropriation for Alaska Energy Authority - Tuluksak Bulk Fuel Upgrades

FY2016 Request: \$0
Reference No: AMD 60718

AP/AL: Appropriation

Project Type: Energy

Category: Development

Location: Tuluksak

House District: Lower Kuskokwim (HD 38)

Impact House District: Lower Kuskokwim (HD 38)

Contact: Sara Fisher-Goad

Estimated Project Dates: 06/30/2015 - 06/30/2019

Contact Phone: (907)771-3000

Brief Summary and Statement of Need:

The unexpended and unobligated balance, not to exceed \$3,900,000 of the estimated balance of \$12,500,000, of the appropriation made in sec. 4, ch. 5, FSSLA 2011, page 137, lines 21-23 (AEA – Mount Spurr Geothermal Project Development - \$12,500,000) is reappropriated to the Alaska Energy Authority for Tuluksak Bulk Fuel Upgrades.

Funding:	<u>FY2016</u>	<u>FY2017</u>	<u>FY2018</u>	<u>FY2019</u>	<u>FY2020</u>	<u>FY2021</u>	<u>Total</u>
Gen Fund							\$0
Total:	\$0	\$0	\$0	\$0	\$0	\$0	\$0

<input type="checkbox"/> State Match Required	<input checked="" type="checkbox"/> One-Time Project	<input type="checkbox"/> Phased - new	<input type="checkbox"/> Phased - underway	<input type="checkbox"/> On-Going
0% = Minimum State Match % Required		<input checked="" type="checkbox"/> Amendment	<input type="checkbox"/> Mental Health Bill	

Operating & Maintenance Costs:

	<u>Amount</u>	<u>Staff</u>
Project Development:	0	0
Ongoing Operating:	0	0
One-Time Startup:	0	0
Totals:	0	0

Prior Funding History / Additional Information:

No prior funding history.

Project Description/Justification:

Funding is needed to consolidate all bulk storage tankage into a code compliant containment facility that houses tankage for each stakeholder in separate, secured areas. Currently the community of Tuluksak has four separate tank farms, three of which are aged, in various stages of disrepair and are not code compliant. Code deficiencies effect environment, and life and health safety. The current tankage does not meet capacity needs and often requires flying in fuel at high cost during winter shortages. The new consolidated bulk fuel storage will include 300,000 gallons of bulk storage; new 1,800 foot dual-product barge header; dual-product dispenser for retail fuel sales; required fuel facility regulatory plans and EPA-required spill contingency equipment.